

# VICTORIA ELECTRIC COOPERATIVE

## Specification for underground on a free standing structure

### RECOMMENDED WIRE SIZE FOR NON-CONTINUOUS LOAD

COPPER	SERVICE AMPS
4	100
3	110
2	125
1	150
1/0	175
2/0	200
3/0	225
4/0	250

### 200 AMP URD PEDESTAL

